



NOTE:

1. HYDRANTS TO BE LOCATED AT LEAST 3' OUTSIDE OF VEHICLE TRAVEL AREAS AND PROTECTED WITH CURB.
2. INSTALL VALVE BOX PER CITY OF COBURG STD DWG WA-002.
3. INSTALL HARRINGTON HYDRANT STORZ CONNECTION ACCORDING TO HPHA™ SPECIFICATION PER DWG NO. HPHA40-45NH/CAP.
4. HYDRANT TO BE RED, FACTORY COATED WITH AN EPOXY PRIMER AND TWO-PART POLYURETHANE TOP COAT.



**CITY OF COBURG
STANDARD DRAWING**

**2B-10 WATEROUS
5-1/4" PACER
FIRE HYDRANT**

DATE:
MAY 2023

DRAWING NO.
WA-003